



Legend

Health Advisory Level (HAL)
HAL is the sum of both PFOA and PFOS
PFOA 70 ng/L, PFOS 70 ng/L

- Sum of PFOA & PFOS concentrations detected above 70 ng/L
- Sum of PFOA & PFOS concentrations detected between 52 ng/L and 70 ng/L
- Sum of PFOA & PFOS concentrations detected at or below 52 ng/L
- PFOA & PFOS not detected
- Location sampled (no results yet)
- Area of Private Wells for Sampling
- Public Water Boundary

Imagery: ESRI, Bing Mapping Service
Sample Data: Weston Generated

Coordinate System:
WGS84 UTM Zone 18N Feet



0 800 1,600
Feet

Blades Groundwater
Blades, Sussex County, DE

Figure 1
PFC Sample Location Map
as of 03/07/2018

TDD#: W
Contract: EP-53-15-02
Prepared: 3/9/2018

